

FIRE DEPARTMENT OF BALTIMORE
FIRE PREVENTION CODE

June 6, 1952.

United Evangelical Church,
East avenue and Dillon street,
Baltimore, Md.

Gentlemen:--

Attention is called to Violation of Ordinance No. 438, approved June 21, 1946, as follows:

PREMISES: N. E. Corner East avenue and Dillon street.

CORRECT BY Fire Prevention Code.

Sec. 3

Par. 306-D

One unit of Class "B" Fire Extinguisher provided and installed in vicinity of fuel oil storage tanks in building on premises.

MUST BE ABATED ON AND AFTER June 16, 1952.

Michael H. Loz.

Chief Engineer—Fire Department.

*Almond
Mr
Ouchman
Wm. H. W. Hitting Co*

FIRE PREVENTION

The Wm. H. Whiting Co.

Marine & Industrial Supplies • Fire Protection Equipment 6-9-52
PRATT & GAY STS. BALTIMORE-2, MD.

United Evangelical Church FIRE PREVENTION CODE

East Ave. & Dillon St.

Balto 24 Md.

Key is at 945 East Ave.

June 6, 1952.

~~Quantity
Ordered~~

Req'n No. al Church,

Order No

Quantity
Shipped

REMARKS

✓ 1 PW12-2½ Gal. Pyrene Foam Ext.

43.00ea 50%

Del and charge.

Attention is called to Violation of Ordinance No. 438, approved June 21, 1946, as follows:

Jenks: Write on tag hang near oil burner.

PREMISES: N. E. Corner East avenue and Dillon street.

CORRECT BY Fire Prevention Code.

Sec. 3
Par. 306-D

One unit of Class "B" Fire Extinguisher provided and installed in vicinity of fuel oil storage tanks in building on premises.

MUST BE ABATED ON AND AFTER June 16,

Rec'd By

Title

Michael H. Logg

Chief Engineer—Fire Department.

*Photo
Mr
Ouchman
Wm. H. Whiting Co*